

**NOTES:**

1. (\*) 18" MINIMUM CLEARANCE REQUIRED FOR WATER AND SEWER MAIN CROSSINGS, 12" MINIMUM CLEARANCE REQUIRED FOR OTHER UTILITY CROSSINGS.
2. THE DEFLECTION TYPE CROSSING SHALL BE USED WHENEVER POSSIBLE. ONLY UNDER SPECIFIC ORDERS BY THE ENGINEER SHALL THE FITTING TYPE CROSSING BE ALLOWED.
3. CONSTRUCT CROSSING USING 75% OF MANUFACTURES MAXIMUM JOINT DEFLECTION (MAXIMUM).


CITY OF PEMBROKE PINES  
ENGINEERING/UTILITIES DIVISION

STANDARD GENERAL DETAIL

APPROVED:     J.M.      
DATE:     11/05/99    

REVISED:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

UTILITY CROSSING  
DEFLECTION TYPE



**G-5**