

NOTES:

1. (*) 18" MINIMUM CLEARANCE REQUIRED FOR WATER AND SEWER MAIN CROSSINGS, 12" MINIMUM CLEARANCE REQUIRED FOR OTHER UTILITY CROSSINGS.
2. COAT TIE RODS WITH A COAL TAR ENAMEL AFTER ASSEMBLY (2 COATS MIN.)
3. TIE RODS MAY BE OMITTED WHEN OTHER APPROVED METHODS OF RESTRAINING ARE UTILIZED.


CITY OF PEMBROKE PINES
ENGINEERING/UTILITIES DIVISION

STANDARD GENERAL DETAIL

APPROVED: J.M.
DATE: 11/05/99

REVISED:

UTILITY CROSSING
FITTING TYPE



G-6