

NOTES:

1. ROUGH IN RISER TO 1 FOOT ABOVE FINISHED GRADE AND CAP. CUT BACK TO FINISHED GRADE DURING PAVING AND/OR PROJECT CLOSE-OUT.
2. CONCRETE SHALL BE CLASS I PORTLAND CEMENT WITH A MINIMUM COMPRESSIVE STRENGTH OF 3,500 PSI AT 28 DAYS.

CITY OF PEMBROKE PINES
ENGINEERING/UTILITIES DIVISION

STANDARD SANITARY
SEWER DETAIL


APPROVED: J.M.

REVISED:

DATE: 11/05/99

10/20/22

CLEAN OUT



S-10