

NOTES:

1. INSIDE DIAMETER OF MANHOLE SHALL BE 6'-0" IF FORCE MAIN IS LARGER THAN 24" DIAMETER.
2. PRECAST CONCRETE MANHOLE ENCLOSURE WITH DOGHOUSE TYPE OPENINGS AND NO BOTTOM.
3. ACTUAL LOCATION OF MANHOLE SHALL BE DETERMINED BY ENGINEER IN THE FIELD.
4. PAINT INTERIOR WITH 2 COATS, AND EXTERIOR WITH 1 COAT OF COAL TAR EPOXY.

CITY OF PEMBROKE PINES
ENGINEERING/UTILITIES DIVISION


STANDARD SANITARY
SEWER DETAIL

APPROVED: J.M.

REVISED:

DATE: 11/05/99

MANHOLE AIR RELEASE VALVE



S-15