



**NOTES:**

1. INSIDE DIAMETER OF MANHOLE SHALL BE 6'-0" IF FORCE MAIN IS LARGER THAN 24" DIAMETER.
2. PRECAST CONCRETE MANHOLE ENCLOSURE WITH DOGHOUSE TYPE OPENINGS AND NO BOTTOM.
3. ACTUAL LOCATION OF MANHOLE SHALL BE DETERMINED BY ENGINEER IN THE FIELD.
4. PAINT INTERIOR WITH 2 COATS, AND EXTERIOR WITH 1 COAT OF COAL TAR EPOXY.
5. ALL CONCRETE STRUCTURES SHALL BE SIGNED AND SEALED BY A FLORIDA-REGISTERED ENGINEER.
6. ALL STAINLESS STEEL SHALL BE 316 OR 316L.

CITY OF PEMBROKE PINES ENGINEERING/UTILITIES DIVISION		STANDARD SANITARY SEWER DETAIL			S-15
APPROVED: <u>    J.M.    </u>	REVISED: <u>    08/10/23    </u>	MANHOLE RELEASE VALVE			
DATE: <u>    11/05/99    </u>					