

**NOTES:**

1. INSIDE DIAMETER OF MANHOLE SHALL BE 6'-0" IF FORCE MAIN IS LARGER THAN 24" DIAMETER.
2. PRECAST CONCRETE MANHOLE ENCLOSURE WITH DOGHOUSE TYPE OPENINGS AND NO BOTTOM.
3. ACTUAL LOCATION OF MANHOLE SHALL BE DETERMINED BY ENGINEER IN THE FIELD.
4. \* FITTINGS MAY BE 1" FOR WATER MAIN 12" OR LESS.

CITY OF PEMBROKE PINES  
ENGINEERING/UTILITIES DIVISION


STANDARD WATER  
DISTRIBUTION DETAIL

APPROVED: J.M.

REVISED:

DATE: 11/05/99

WATER AIR RELEASE VALVE



W-7