

NOTES:


1. SIDES AND TOP OF TRENCH ONLY TO BE LINED WITH FILTER FABRIC. OVERLAP LINER A MINIMUM OF 2' AT THE TOP OF THE TRENCH.
2. BALLAST ROCK SHALL BE FROM FRESH WATER, WASHED AND FREE OF DELETERIOUS MATTER.
3. ALL EXFILTRATION TRENCHES SHALL HAVE A POLLUTION RETARDANT BAFFLE AT EACH CONNECTION POINT OF STRUCTURE. (SEE POLLUTION RETARDANT BAFFLE DETAIL.)
4. GASKETS SHALL BE USED WITH RCP IN EXFILTRATION TRENCH.

CITY OF PEMBROKE PINES
ENGINEERING/UTILITIES DIVISION

STANDARD DRAINAGE DETAIL

APPROVED: J.M. REVISED: _____
DATE: 11/05/99 _____

EXFILTRATION TRENCH



D-7