



NOTE:
SIGN SHALL HAVE WHITE BACKGROUND WITH RED LETTERS AND SHALL BE 7' IN HEIGHT TO BOTTOM OF SIGN. ALL SIGNS SHALL FACE THE FLOW OF TRAFFIC AND BE A MAXIMUM OF 60' APART.



"NO PARKING FIRE LANE"
SIGN (18"x24")
PER N.F.P.A. 18.2(3)(5)3

SQUARE TUBE
SIGN POST
PER B.C.T.E.D.
STANDARDS

FINISHED GRADE/
SURFACE

NOTES:

1. ALL PAVEMENT MARKINGS SHALL BE THERMOPLASTIC.
2. SIGN SHALL BE "DIAMOND GRADE" TYPE MEETING BROWARD COUNTY TRAFFIC ENGINEERING DIVISION (B.C.T.E.D.) STANDARDS FOR SIGNS.
3. PRIOR TO REINSTALLATION OF FIRE LANE PAVEMENT MARKINGS IN ASSOCIATION WITH SEALCOATING AND/OR REPAVING OF ANY EXISTING COMMERCIAL, RETAIL, INDUSTRIAL OR OFFICE TYPE PROJECT, "PROJECT SPECIFIC" "FIRE LANE LIMITS" MUST BE DETERMINED BY A FIELD REVIEW OF THE EXISTING PROJECT CONDITIONS BY FIRE PREVENTION BUREAU. ONLY FIRE LANE MARKINGS AND SIGNAGE SHALL BE INSTALLED IN THOSE SITE SPECIFIC LOCATIONS AS FIELD IDENTIFIED BY THE FIRE PREVENTION BUREAU.

CITY OF PEMBROKE PINES ENGINEERING/UTILITIES DIVISION		STANDARD ROAD DETAIL			<h1>R-43</h1>
APPROVED: <u> K.M.K. </u>	REVISED: <u> 06/26/19 </u>	FIRE LANE MARKING AND SIGNAGE			
DATE: <u> 08/29/17 </u>	_____				