

Mission:
To protect, promote & improve the health
of all people in Florida through integrated
state, county & community efforts.



Rick Scott
Governor

Celeste Philip, MD, MPH
State Surgeon General

Vision: To be the Healthiest State in the Nation

Florida Department of Health in Broward County
Drinking Water Program
August 22, 2018

MEMORANDUM

TO: 4061083 – City of Pembroke Pines PWS

SUBJECT: DBP Stage II Reduced Monitoring

Dear Public Water System Owner:

This letter is to inform you that after reviewing our records and your communication dated August 1, 2018, we have determined that the City of Pembroke Pines Public Water System **meets** the requirements of §141.623(a), Code of Federal Regulations (CFR), to reduce the monitoring of disinfection by-products under Stage 2 Regulations.

As required by §141.623(a), CFR, **the monitoring frequency will be quarterly**, with samples collected at the following locations:

Location	Contaminant/Number of samples	Frequency
MP3: 901 NW 208 th Ave./Rose Price Park	TTHM/ One (1) sample	Quarterly
	HHA5/ One (1) sample	
MP8: 20426 SW 54 th PL	TTHM/ One (1) sample	Quarterly
	HHA5/ One (1) sample	

The attached sampling plan submitted August 1, 2018 has been approved. The system may remain on reduced monitoring as long as the TTHM LRAA ≤ 0.040 mg/L and the HAA5 LRAA ≤ 0.030 mg/L at each monitoring location (§141.623(b)). Should any single sample result exceed the above-mentioned levels, the City of Pembroke Pines Public Water System must return to increased monitoring frequency.

Respectfully,

Sandra E. Giraldo, MA, MPH

Engineer IV

Florida Department of Health in Broward County